

<b>Testing Period</b>	<b>PA DEP*</b> Maximum Contaminant Level for PFOA (ng/L or ppt)	<b>PA DEP*</b> Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	<b>US EPA**</b> Maximum Contaminant Level for PFOA (ng/L or ppt)	<b>US EPA**</b> Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	<b>MAWSA</b> PFOA Test result (ng/L or ppt)	<b>PA DEP*</b> Maximum Contaminant Level Goal for PFOS (ng/L or ppt)	<b>PA DEP*</b> Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	<b>US EPA**</b> Maximum Contaminant Level Goal for PFOS (ng/L or ppt)	<b>US EPA**</b> Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	<b>MAWSA</b> PFOS Test result (ng/L or ppt)
2024 Q1	14.0	8.0	4.0	0.0	11.0	18.0	14.0	4.0	0.0	7.4
2024 Q2	14.0	8.0	4.0	0.0	8.2	18.0	14.0	4.0	0.0	6.5
2024 Q3	14.0	8.0	4.0	0.0	10.0	18.0	14.0	4.0	0.0	6.6
2024 Q4	14.0	8.0	4.0	0.0	11.0	18.0	14.0	4.0	0.0	7.1

\* Current Pennsylvania DEP guidelines in place

\*\* Recently-announced Federal enforceable limits (MCL) and goals (MCLG) beginning in 2029