



Testing Period	PA DEP* Maximum Contaminant Level for PFOA (ng/L or ppt)	PA DEP* Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	US EPA** Maximum Contaminant Level for PFOA (ng/L or ppt)	US EPA** Maximum Contaminant Level Goal for PFOA (ng/L or ppt)	MAWSA PFOA Test result (ng/L or ppt)	PA DEP* Maximum Contaminant Level for PFOS (ng/L or ppt)	PA DEP* Maximum Contaminant Level Goal for PFOS (ng/L or ppt)	US EPA** Maximum Contaminant Level for PFOS (ng/L or ppt)	US EPA** Maximum Contaminant Level Goal for PFOS (ng/L or ppt)	MAWSA PFOS Test result (ng/L or ppt)
2024 Q1	14.0	8.0	4.0	0.0	11.0	18.0	14.0	4.0	0.0	7.4
2024 Q2	14.0	8.0	4.0	0.0	8.2	18.0	14.0	4.0	0.0	6.5
2024 Q3	14.0	8.0	4.0	0.0	10.0	18.0	14.0	4.0	0.0	6.6
2024 Q4	14.0	8.0	4.0	0.0	11.0	18.0	14.0	4.0	0.0	7.1
2025 Q1	14.0	8.0	4.0	0.0	12.6	18.0	14.0	4.0	0.0	7.4
2025 Q2	14.0	8.0	4.0	0.0	9.9	18.0	14.0	4.0	0.0	6.5
2025 Q3	14.0	8.0	4.0	0.0	7.4	18.0	14.0	4.0	0.0	6.0
2025 Q4	14.0	8.0	4.0	0.0	10.0	18.0	14.0	4.0	0.0	6.9
2026 Q1	14.0	8.0	4.0	0.0	10.0	18.0	14.0	4.0	0.0	7.7
2026 Q2	14.0	8.0	4.0	0.0	10.0	18.0	14.0	4.0	0.0	7.0
2026 Q3	14.0	8.0	4.0	0.0	11.2	18.0	14.0	4.0	0.0	8.4

* Current Pennsylvania DEP limits in place

** New Federal enforceable limits (MCL) and goals (MCLG) beginning in 2031